

## BRE Global Ireland

**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance 2831-CPR-F0161

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

### ASW2367 Analogue Addressable Type A Sounder and Wall Mounted Red Light LED Visual Alarm Device

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

**Carrier Fire and Security B.V.**  
Kelvinstraat 7  
Weert  
NL-6003 DH  
Netherlands

**Texecom Ltd**  
Bradwood Court, St Crispin Way  
Haslingden  
Lancashire  
BB4 4PW  
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-3:2001 + A1:2002 + A2:2006 - Sounders EN 54-23:2010 - Visual alarm devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Z Major, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Issue Date: 14 August 2024

Issue Number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland****Approved Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F0161****ASW2367 Analogue Addressable Type A Sounder and Wall Mounted Red Light LED Visual Alarm Device****Bases:**

PSO-0017 / HSG6918 – Red Deep base

**Notes:**

1. ASW2367 – Red Body (red lens + red light LED) Type A – use base PSO-0017 / HSG6918
2. The sounder meets the requirements of EN 54-3 at the following tones:
  - 1) 970Hz continuous
  - 2) 800Hz/970Hz @ 2Hz
  - 3) 800Hz – 970Hz @ 1Hz
  - 6) 554Hz, 0.1s/ 440Hz, 0.4s
  - 7) 500 – 1200Hz, 3.5s/ 0.5s OFF
  - 13) 1200Hz – 500Hz @ 1Hz
3. The VAD meets the requirements of EN 54-23 for the following:
  - Category W-3-7.49
  - Flash rates 0.5Hz and 1Hz
  - Synchronization



Z Major, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Issue Date: 14 August 2024

Issue Number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)