



Certificate of Continued Compliance 222350062/AA/00



Issued	10-07-2023	Replaces	
Expiry date	10-07-2027	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	Axon control panel 32 zones - 4 areas - medium metal
Trademark:	ARITECH
Type designation:	ATS1700-MM
Serial No:	N/A
Hardware / Software:	R55-1070-03-B / MR_1.0
Variants:	See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer:	Carrier Fire & Security B.V.
Address:	Kelvinstraat 7
City:	6003DH Weert
Country:	Netherlands

This certificate is granted to:

Name of the certificate holder:	Carrier Fire & Security B.V.
Address:	Kelvinstraat 7
City:	6003DH Weert
Country:	Netherlands

Ron Scheepers
Managing director

This certificate has THREE Annexes.

CERTIFICATE

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Security grade: 3

Environmental class: II

Equipment class: Fixed

Power supply type: A

SPT structure: Type Z

ATS category:

- SP4: IP with Ultrasync
- SP5: IP with OH receiver, GPRS with OH or Ultrasync receiver
- DP3: IP and GPRS with Ultrasync receiver
- DP4: IP and GPRS with OH receiver

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Carrier Manufacturing Polska Sp. z o.o.

24 Kolejowa street

Ropczyce

Poland

Product inspection location:

Carrier Fire & Security B.V.

Kelvinstraat 7

Weert

Netherlands

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Kiwa Nederland B.V.: P000240476-ENV-Ver 1.00, 23 June 2023
- Kiwa Nederland B.V.: P000240476-001-Ver 1.00, 23 June 2023
- Kiwa Nederland B.V.: P000240476-002-Ver 1.00, 26 June 2023
- Kiwa Nederland B.V.: P000240476-003-Ver 1.00, 23 March 2023

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10	June, 2014
EN 50131-3	March, 2009

Applied Standards

EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-6+A1	June, 2021
EN 50136-1+A1	November, 2018
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- Product description: Axon control panel 32 zones - 4 areas - medium metal
- Trademark: ARITECH
- Type designation: ATS1700-MM
- Hardware version: R55-1070-03-B
- Software version: MR_1.0
- Serial number: N/A

- Product description: Axon control panel 1000 zones - 256 areas large metal
- Trademark: ARITECH
- Type designation: ATS4700-LM
- Hardware version: R55-1070-03-B
- Software version: MR_1.0
- Serial number: N/A

- Product description: Control panel: MM housing, SDPRO-MBC-1, ATsx700-PSU
- Trademark: ARITECH
- Type designation: SDPRO-CP-1
- Hardware version: R55-1070-03-B
- Software version: MR_1.0
- Serial number: N/A