



INCERT CERTIFICATE

C-001-1649/b



Issued 31-07-2024
Expiry date 13-02-2026

Replaces C-001-1649/a
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Axon control panel 32 zones - 4 areas - medium metal
Trademark: ARITECH
Type designation: ATS1700-MM
Hardware / Software: R55-1070-03-B / MR_3.x
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Carrier Fire & Security B.V.
Address: Kelvinstraat 7
City: 6003DH Weert
Country: Netherlands

This certificate is granted to:

Name of the certificate holder: Carrier Fire & Security EMEA bvba
Address: De Kleetlaan 3
City: 1831 Diegem
Country: Belgium

Ron Scheepers
Managing director

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



CERTIFICATE

Remarks and observations

The following conditions are applicable:

Category: Central Panel

Security grade: 3

Environmental class: II

Equipment class: Fixed

Power supply type: A

SPT structure: Type Z

ATS category:

- SP4: IP with Ultrasync receiver
- SP5: IP with OH receiver

In combination with GSM module : ATS7340 or ATS7341

- SP5: GPRS with OH or Ultrasync receiver
- DP3: IP and GPRS with Ultrasync receiver
- DP4: IP and GPRS with OH receiver

In combination with GSM module ATS7341

- DP4: IP and GPRS with Ultrasync receiver

The x visible in the sw version stands for a digit that can change in case of minor changes.

The certified version is recorded in the certification file together with any reported minor changes.

Factory location:

Carrier Manufacturing Polska Sp. z o.o.

24 Kolejowa street

Ropczyce

Poland

Product inspection location:

Carrier Fire & Security B.V.

Kelvinstraat 7

Weert

Netherlands

Documentation lodged for this INCERT certificate

Test Reports:

- Kiwa Nederland B.V.: P000240476-ENV-Ver 1.00, 23 June 2023
- Kiwa Nederland B.V.: P000240476-001-Ver 1.00, 23 June 2023
- Kiwa Nederland B.V.: P000240476-002-Ver 1.00, 26 June 2023
- Kiwa Nederland B.V.: P000240476-003-Ver 2.00, 28 June 2024
- Kiwa Nederland B.V.: P000240476-004-Ver 1.00, 01 September 2023

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1+A2

August, 2022

Applied Standards

EN 50131-3	March, 2009
EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-10	June, 2014
EN 50130-4+A1	October, 2014
EN 50131-6+A1	June, 2021
EN 50136-1+A1	November, 2018
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- Product description: Axon control panel 32 zones - 4 areas - medium metal
- Trademark: ARITECH
- Type designation: ATS1700-MM
- Hardware version: R55-1070-03-B
- Software version: MR_3.x

- Product description: Axon control panel 256 zones - 16 areas - medium metal
- Trademark: ARITECH
- Type designation: ATS3700-MM
- Hardware version: R55-1070-03-B
- Software version: MR_3.x