

Certificate of Product Approval

Certificate Number: 1062f

Issue: 01

UTC Fire & Security B.V.

Kelvinstraat 7
NL-6003 DH Weert
The Netherlands



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Flame Detectors

FF746
FF766
FF756
FF747
FF767
FF742
FF751

(refer to Appendix for details)

Standards

EN 54-10:2002 + A1:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

15 May 2018

Date of Issue

15 May 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1062f

Issue: 01

UTC Fire & Security B.V.

Certified Product	Description	LPCB Ref.No.
FF746	Edwards Conventional IR ² (Exd) Flameproof Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/01
FF766	Edwards Conventional IR ³ (Exd) Flameproof Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/02
FF756	Edwards Conventional UV/IR ² (Exd) Flameproof Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/03
FF747	Edwards Conventional IR ² Intrinsically Safe Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/04
FF767	Edwards Conventional IR ³ (IS) Intrinsically Safe Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/05
FF742	Edwards Conventional IR ² Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/06
FF762	Edwards Conventional IR ³ Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/07
FF751	Edwards Conventional UV/IR ² Flame Detector (FF705 Bracket) Note: Meets EN 54-10:2002 at Class 1 Only	1062f/08

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan

Signed for BRE Global Ltd

P Halligan

Verifier

15 May 2018

Date of Issue

15 May 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1062f UTC Fire & Security B.V.

Issue: 01

Ancillaries

FF705 Adjustable Mounting Bracket

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

15 May 2018
Date of Issue

15 May 2018
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre