

# ModuLaser Modular Aspirating System Display Module Compatibility List

#### Introduction

This document lists the products compatible with your ModuLaser aspirating system display modules.

**Caution:** Compatible products may change without notice. Always contact your local supplier to confirm availability and compatibility.

#### ModuLaser command module

The following products are compatible with your ModuLaser command module.

Model [1]	Description
9-30780	Stratos ModuLaser minimum display module
9-30781	Stratos ModuLaser standard display module
9-30783	Stratos ModuLaser detector module
9-30621-xxx	Stratos HSSD-2 aspirating smoke detector
9-30706	Stratos HSSD-2 aspirating smoke detector (steel housing)
9-30710-xxx	Stratos HSSD-2 aspirating smoke detector (with minimum display)
9-30672-xxx	Stratos Micra 100 aspirating smoke detector
9-30764-xxx	Stratos Micra 100 aspirating smoke detector (with relay input card)
9-30671-xxx	Stratos Micra 25 aspirating smoke detector
9-30760-xxx	Stratos Micra 25 aspirating smoke detector (with relay input card)
9-30802	SenseNET RDU for 19" rack mount
9-30430	Apollo APIC
9-30437 [2]	Ziton APIC

<sup>[1]</sup> Where –xxx indicates localized and/or international variants of listed models.

## ModuLaser standard and minimum displays

The following products are compatible with your ModuLaser standard and minimum displays.

Model	Description
9-30782	Stratos ModuLaser command display module
9-30802	SenseNET RDU for 19" rack mount
9-30430	Apollo APIC
9-30437 [1]	Ziton APIC

[1] This product conforms to EN 54-20 requirements, but note that no CPR certificate is available.

### **Contact information**

For further information on any product listed, contact your local supplier or see <a href="https://firesecurityproducts.com">https://firesecurityproducts.com</a>.

## **Product warnings and disclaimers**

THESE PRODUCTS ARE INTENDED FOR SALE TO AND INSTALLATION BY QUALIFIED PROFESSIONALS. UTC FIRE & SECURITY CANNOT PROVIDE ANY ASSURANCE THAT ANY PERSON OR ENTITY BUYING ITS PRODUCTS, INCLUDING ANY "AUTHORIZED DEALER" OR "AUTHORIZED RESELLER", IS PROPERLY TRAINED OR EXPERIENCED TO CORRECTLY INSTALL FIRE AND SECURITY RELATED PRODUCTS.

For more information on warranty disclaimers and product safety information, please check <a href="https://firesecurityproducts.com/policy/product-warning/">https://firesecurityproducts.com/policy/product-warning/</a> or scan the QR code:



<sup>[2]</sup> This product conforms to EN 54-20 requirements, but note that no CPR certificate is available.