

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: SensoIRIS MC-D
Description: Addressable fire alarm module conventional zone with built-in isolator module

Complies to the following standards:

EN 54-17:2005; EN 54-17:2005/AC:2007
EN 54-18:2005; EN 54-18:2005/AC:2007
EN 55032:2015
EN 50130-4:2011; EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011
REACH № 1907/2006

And the following Directives:

2014/30/EU- EMC
2011/65/EU- RoHS II

Additional information:

First date of production: 05.2020

Certificate:

№1293-CPR-0701 of October 28, 2020 from Notified body № 1293 EVPU

Test report:

№ 9-0023/20 of October 28, 2020 from Notified body № 1293 EVPU

1407 Sofia,
14A, Srebarna Str.
24.11.2020

Yuliy Iliev
Quality Manager

