

Declaration of performance

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

SensoIRIS MOUT-240

2. *Type Number:*

SensoIRIS MOUT-240

Description: Potential output for conventional sounder

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

Fire detection and fire alarm systems installed in and around buildings

4. *Manufacturer*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

6. *System of assessment*

System 1

7. *No European Technical Assessment has been issued for this product.*

Teletek Electronics JSC

14A, Srebarna Str.
1407 Sofia, Bulgaria
www.teletek-electronics.com

Tel.: (+359 2) 969 47 00
Fax: (+359 2) 962 52 13
info@teletek-electronics.bg



ISO 9001 Certified Company

8. *Declared performance*

EN 54-18:2005+AC:2007 Fire detection and fire alarm systems - Part 18: Input/output devices		
Clause	Description	Performance
4	Requiments	Pass
4.1	Compliance	Pass
4.3	Marking and data	Pass
4.4	Documentation	Pass
4.5	Requirements for software controlled devices	Pass
5	Test	Pass
5.1	General	Pass
5.2	Performance and variation in supply parameters	Pass
5.3	Dry heat (operational)	Pass
5.4	Cold (operational)	Pass
5.5	Damp heat, cyclic (operational)	Pass
5.6	Damp heat, steady state (endurance)	Pass
5.7	Sulphur dioxide (SO ₂) corrosion (endurance)	Pass
5.8	Shock (operational)	Pass
5.9	Impact (operational)	Pass
5.10	Vibration, sinusoidal (operational)	Pass
5.11	Vibration, sinusoidal (endurance)	Pass
5.12	Electromagnetic, Compatibility (EMC) Immunity tests	Pass

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia,
14A, Srebarna Str.
24.02.2014

Irina Georgieva
Quality Manager

