

Declaration of performance

№ 023/2015

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

SensoIRIS S130

2. *Type Number:*

SensoIRIS S130

Description:

Intelligent analogue addressable fire alarm optical smoke detector

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

Fire detection and fire alarm systems installed in and around buildings

4. *Manufacturer*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

6. *System of assessment*

System 1

7. *Notified Body*

**EVPU a.s.
19 Trencianska Str.
018 51 Nova Dubnica, Slovakia**

Notified Body Number

1293

EC Certificate Number

1293- CPR-0452-Rev.1

8. *No European Technical Assessment has been issued for this product.*

9. Declared performance

Essential characteristics	Performance	Harmonized technical specification EN 54-7:2018
Operational reliability	Pass	cl. 4.2.1 to 4.2.8
Nominal activation conditions/Sensitivity	Pass	cl. 4.3.1 to 4.3.3
Response delay (response time)	Pass	cl. 4.4.1, 4.4.2
Tolerance to supply voltage	Pass	cl. 4.5
Performance parameters under fire conditions	Pass	cl. 4.6
Durability of Nominal activation condition / Sensitivity; Temperature resistance	Pass	cl. 4.7.1.1, 4.7.1.2
Durability of Nominal activation condition / Sensitivity; Humidity resistance	Pass	cl. 4.7.2.1, 4.7.2.2
Durability of Nominal activation condition / Sensitivity; Corrosion resistance	Pass	cl. 4.7.3
Durability of Nominal activation condition / Sensitivity; Vibration resistance	Pass	cl. 4.7.4.1 to 4.7.4.4
Durability of Nominal activation condition / Sensitivity; Electrical stability	Pass	cl. 4.7.5

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Note: To be used in conjunction with base B124.

Signed for and on behalf of the manufacturer by:

1407 Sofia,
14A, Srebarna Str.
24.06.2022

Yuliy Iliev
Quality Manager

