

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose str.
1220 Sofia, Bulgaria

Declares that the

Product: iRIS4

Description: Expandable addressable Fire Alarm Control Panel

Complies with the following standards:

EN 54-2:1997; EN 54-2:1997/AC:1999; EN 54-2:1997/A1:2006

EN 54-4:1997; EN 54-4:1997/AC:1999;

EN 54-4:1997/A1:2002; EN 54-4:1997/A2:2006

EN 62368-1:2023

EN 55032:2015

EN 61000-3-2:2006

EN 61000-3-3:2013

The following Regulation:

CPR № 305/2011

REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC

2014/35/EU- LVD

2011/65/EU- RoHS II

Additional information:

First date of production: 09.2023

Certificate:

№ 1293-CPR-0866 of September 25th, 2023 from Notified body № 1293 EVPÚ a.s.

Test report:

№ 9-0013/23 of April 26, 2023 from Notified body № 1293 EVPÚ a.s.

№0-0076B/25 of April 10, 2025 from Notified body № 1293 EVPÚ a.s.

2, Iliyansko shose str.
1220 Sofia, Bulgaria
09.06.2025

Alek Artinyan
Quality Manager

