

Declaration of performance

№ 246/2023

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

iRIS4

2. *Type Number:*

iRIS4

Description:

Expandable addressable fire alarm control panel

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

Fire detection and fire alarm systems installed in and around buildings

4. *Manufacturer*

**Teletek Electronics JSC
2 Iliyansko shose Str
1220 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC
2 Iliyansko shose Str
1220 Sofia, Bulgaria**

6. *System of assessment*

System 1

7. *Notified Body*

**EVPU a.s.
Trenčianska 19, 018 51 Nová Dubnica, Slovak Republic**

Notified Body Number

1293

Performed **the prescribed tests and evaluation of factory production control
according to system 1 and issued the following certificate**

EC Certificate Number

1293 – CPR - 0866

8. *No European Technical Assessment has been issued for this product.*

9. *Declared performance*

Essential characteristics	Performance	Harmonized technical specification EN 54-2:1997 EN 54-2:1997/AC:1999 EN 54-2:1997/A1:2006
Performance under fire conditions	Pass	4, 5, 7
Response delay (response time to fire)	Pass	7.1, 7.7, 7.11, 7.12
Operational reliability	Pass	4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14
Durability of operational reliability, Temperature resistance	Pass	15.4
Durability of operational reliability, Vibration resistance	Pass	15.6, 15.7, 15.15
Durability of operational reliability, Electrical stability	Pass	15.8, 15.13
Durability of operational reliability: humidity resistance	Pass	15.5, 15.14

Essential characteristics	Performance	Harmonized technical specification EN 54-4:1997 EN 54-4:1997/AC:1999 EN 54-4:1997/A1:2002 EN 54-4:1997/A2:2006
Performance of power supply	Pass	4, 5, 6
Operational reliability	Pass	4, 5, 6, 7, 8
Durability of operational reliability, Temperature resistance	Pass	9.5
Durability of operational reliability, Vibration resistance	Pass	9.7, 9.8, 9.15
Durability of operational reliability, Electrical stability	Pass	9.9
Durability of operational reliability: humidity resistance	Pass	9.6, 9.14

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1220 Sofia,
2, Iliyansko shose str.
09.06.2025

Alek Artinyan
Quality Manager

