

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: SIMPO
Description: Intelligent interactive analogue addressable fire alarm control panel

Complies to the following standards:

EN 54-2:1997+A1:2006
EN 54-4:1997+A1:2002+A2:2006
EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011+ A2:2013
EN 55032:2015
EN 50130-4:2011/A1:2014
EN 61000-3-2:2006 + A1:2009 + A2:2009
EN 61000-3-3:2008

The following Regulation:

CPR № 305/2011
REACH № 1907/2006

And the following Directives:

2014/30/EU - EMC
2014/35/EC- LVD
2011/65/EU- RoHS II

Additional information:

First date of production: 09.2013

Certificate:

№1293–CPR-0401 of March 25, 2014 from Notified body № 1293 EVPU

Test report:

№ 00008/2014/C of March 25, 2014 from Notified body № 1293 EVPU

1407 Sofia,
14A, Srebarna Str.
14.07.2017

Yuliy Iliev
Quality Manager

